(d) whether the power break-downs in Malaviya Nagar have increased as compared to other adjoining colonies and if so, what steps are being taken to improve the situation?

THE MINISTER OF STATE IN THE DEPARTMENT OF POWER IN THE MINISTRY OF ENERGY (SHRIMATI SUSHILA ROHATGI): (a) and (b) According to Delhi Electric Supply Undertaking, there had been 12 power break-downs on High Voltage system and 21 break-downs on low voltage system in Malaviya Nagar during February, 87 to July, 87 (upto 29.7.87) mainly on account of vagaries of weather, transient faults and load growth in the area.

(c) and (d) According to Delhi Electric Supply Undertaking, the number of break-downs has been more in Malaviya Nagar as compared to other adjoining colonies because of unplanned load growth in the area. Besides carrying out routine maintenance, DESU has augmented the system by adding 770 KVA transformation capacity and 7 low tension feeders in the area. Schemes for addition of 1030 KVA additional transformation capacity with 14 low tension feeders have also been framed by Delhi Electric Supply Undertaking to improve power supply in the area.

दादरी सुपर ताप बिजलीघर

977. **श्री शांति त्यागी:** क्या ऊर्जा मंत्री यह बताने की कृपा करेंगे कि :

(क) दादरी सुपर ताप बिजलीघर परियोजना के कब तक पूरी होने की संभावना है और इस परियोजना पर कितनी धनराशि खर्च होने की संभावना है ;

(ख) उक्त धनराशि किन-किन स्रोतों से उपलब्ध करायी जायेगी ; और

(ग) इस परियोजना के लिये किसानों से अधिग्रहीत की गई भूमि के लिये उन्हें किस दर से मुआवजा दिया गया है ?

ऊर्जा मंत्रालय में विद्युत विभाग में राज्य मंत्री (श्रीमती सुशीला रोहतगी): (क) और (ख) राष्ट्रीय राजधानी ताप विद्युत परियोजना (4×210 मेगावाट), जो कि उत्तर प्रदेश के गाजियाबाद जिले में दादरी के समीप स्थित है, की पहली यूनिट 1991-92 में तथा परवर्ती यूनिटें उसके बाद छः छः महीने के अन्तराल से चालू किए जाने की संभावना है । यह परियोजना 1063.60 करोड़ रुपए की अनुमानित लागत पर अनुमोदित की गई है तथा इसकी वित्त व्यवस्था आंशिक रूप से विश्व बैंक से ऋण के जरिए और आंशिक रूप से राष्ट्रीय ताप विद्युत निगम के योजना आबंटनों और आन्तरिक संसाधनों जिसमें बाण्ड शामिल हैं, से की जाएगी ।

(ग) परियोजना के लिए अधिग्रहीत की गई भूमि के स्वरूप पर निर्भर करते हुए भू-स्वामियों को दिए गए मुआवजे की दर प्रति बीघा 2290 रुपये से 23700 रुपए तक भिन्न-भिन्न हैं ।

Power supply by DESU to shoe factory

978. SHRI CHATURANAN MISHRA: Will the Minister of ENERGY be pleased to state:

(a) whether DESU had sanctioned industrial power supply to a shoe factory established on unauthorised premises near Mundka village, next to Nangloi in North-West Delhi; and

(b) if so, what are the details thereof?

THE MINISTER OF STATE IN THE DEPARTMENT OF POWER IN THE MINISTRY OF ENERGY (SHRIMATI SUSHILA ROHATGI): (a) and (b) The information is being collected and will be laid on the Table of the House.

Engagement of private contractors by ECI

979. SHRI CHATURANAN MISHRA:
SHRI GURUDAS DAS GUPTA:

Will the Minister of ENERGY be pleased to state:

(a) whether it is a fact that private contractors have been engaged in coal